

The following is a list of inspection points for you to check prior to calling for health department inspection.

1. Check the motor to make sure that it is installed and running. Running it continuously is recommended rather than having it on a timer.
2. Check lids and risers to make sure that they aren't missing, broken or crumbling.
3. Check the aerator tank to determine if it needs to be pumped. The effluent at the outlet should be clear with no odor. The inlet end may have a scum layer, but it should be no more than a couple of inches thick.
4. Clean any weeds or sludge accumulation from the sand filter. Check the cover for broken or rotting boards.
5. Locate the discharge point and make sure that there is a slotted cap (animal guard) on the end of the pipe. Any dirt or weeds that block the discharge will need to be removed.

Please contact Gary Radabaugh, R.S. at (740) 286-5094, extension 2829 or David Ramby, R.S. at ext. 2836 if you should have any questions.